

EU SEER/SCOP Test

欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:	<input checked="" type="checkbox"/> (EU) No 626/2011	<input checked="" type="checkbox"/> (EU) No 206/2012	<input checked="" type="checkbox"/> EN14825	<input checked="" type="checkbox"/> EN 14511	<input checked="" type="checkbox"/> ENV 12102	<input type="checkbox"/> Other _____
---------------------	--	--	---	--	---	--------------------------------------

GPA requirement: 产品审批要求:	
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)	>=100%
GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)	>=100%
GPA requirement for Sound Power GPA 的声功率要求	<=Rated
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多分体机	

Model: 型号:		Manufacturer Model: 工厂型号:	AST-12UW4RXVQE00
---------------	--	------------------------------	------------------

Test Result:

Function (indicate to which function information applies)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.					
Cooling		Y		Average (mandatory)		Y			
Heating		Y		Warmer (if designated)		Y			
				Colder (if designated)		N			

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
Design load					Seasonal efficiency				
cooling	Pdesignc	3.5	3.505	kW	cooling	SEER	8.5	8.51	—
heating/Average	Pdesignh	2.6	2.607	kW	heating/Average	SCOP(A)	5.1	5.10	—
heating/Warmer	Pdesignh	3.5	3.520	kW	heating/Warmer	SCOP(W)	5.6	5.61	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	3.5	3.505	kW	Tj = 35 °C	EERd	4.4	4.45	—
Tj = 30 °C	Pdc	2.6	2.603	kW	Tj = 30 °C	EERd	7.4	7.48	—
Tj = 25 °C	Pdc	1.6	1.681	kW	Tj = 25 °C	EERd	10.4	10.43	—
Tj = 20 °C	Pdc	1.6	1.636	kW	Tj = 20 °C	EERd	14.0	14.03	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	2.2	2.229	kW	Tj = -7 °C	COPd	3.4	3.42	—
Tj = 2 °C	Pdh	1.3	1.371	kW	Tj = 2 °C	COPd	5.2	5.28	—
Tj = 7 °C	Pdh	1.6	1.689	kW	Tj = 7 °C	COPd	6.6	6.64	—
Tj = 12 °C	Pdh	0.7	0.768	kW	Tj = 12 °C	COPd	9.3	9.35	—
Tj = operating limit	Pdh	2.0	2.055	kW	Tj = operating limit	COPd	3.1	3.16	—
Tj = bivalent temperature	Pdh	2.2	2.229	kW	Tj = bivalent temperature	COPd	3.4	3.42	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	2.60	2.631	kW	Tj = 2 °C	COPd	4.0	4.07	—
Tj = 7 °C	Pdh	2.30	2.324	kW	Tj = 7 °C	COPd	5.4	5.46	—
Tj = 12 °C	Pdh	1.10	1.143	kW	Tj = 12 °C	COPd	7.2	7.21	—
Tj = operating limit	Pdh	2.60	2.631	kW	Tj = operating limit	COPd	4.0	4.07	—
Tj = bivalent temperature	Pdh	3.00	3.002	kW	Tj = bivalent temperature	COPd	3.7	3.70	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—

Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—
Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	NA	NA	°C	heating/Warmer	Tol	NA	NA	°C
heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	Pcycc	NA	NA	kW	cooling	EERcyc	NA	NA	—
heating	Pcyh	NA	NA	kW	heating	COPcyc	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.00032	0.00032	kW	cooling	Q _{CE}	144	144	kWh/a
standby mode	P _{SB}	0.00100	0.00095	kW	heating/Average	Q _{HE}	714	716	kWh/a
thermostat-off mode	P _{TO}	0.032	0.032	kW	heating/Warmer	Q _{HE}	875	878	kWh/a
crankcase heater mode	P _{CK}	NA	NA	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	54	53.8	dB(A)
					Sound power level (outdoor)	LWA	61	60.6	dB(A)
staged	N				Global warming potential	GWP	675	NA	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

梁梓宇

梁梓宇

Tested by (name + signature)

Approved by (name + signature)

测试员 (姓名, 签名)

批准人 (姓名, 签名)